



**LIMITED ASBESTOS
INSPECTION**

**THE JAMES' HOUSE
42 GOTHIC STREET
NORTHAMPTON,
MASSACHUSETTS**

A large, light-colored circular graphic dominates the left side of the page. Inside the circle is a dark silhouette of a tree. A horizontal band, darker than the circle's background, passes behind the tree's trunk. The text "WHERE BUSINESS AND THE ENVIRONMENT CONVERGE" is printed in white, uppercase letters within this band.

WHERE BUSINESS AND THE ENVIRONMENT CONVERGE

Prepared for:
Northampton Central Services
240 Main Street
Northampton, MA 01060

Project No. 01-211621
Document No. 37130
February 10, 2009

Prepared by:
588 Silver Street
Agawam, MA 01001
tel 413.789.3530 fax 413.789.2776
www.ecsconsult.com

TABLE OF CONTENTS

| | |
|---|---|
| EXECUTIVE SUMMARY | i |
| 1.0 INTRODUCTION | 1 |
| 1.1 LIMITATIONS | 1 |
| 2.0 METHODS AND MATERIALS | 2 |
| 2.1 ASBESTOS | 2 |
| 3.0 RESULTS AND FINDINGS | 3 |
| 4.0 DISCUSSION AND INTERPRETATION | 6 |
| 4.1 ASBESTOS | 6 |


APPENDICES:

Appendix A Laboratory Data


EXECUTIVE SUMMARY

Environmental Compliance Services, Inc. (ECS) has completed a limited inspection for asbestos containing materials (ACM), in the James' House, located on 42 Gothic Street in Northampton, Massachusetts. The inspection was performed on building materials that may be disturbed during future renovation activities. On January 20, 2009 ECS inspectors, using a combination of destructive and non-destructive sampling methods, collected 49 bulk samples of suspect asbestos containing materials. Those materials have been analyzed using the required protocols at an accredited laboratory. A review of the laboratory results indicate that **asbestos containing materials were detected** at this location.

Inspector Signature:



Christopher A. Coelho
Field Technician I, MA Asbestos Inspector # AI072176



Christopher L. Godfrey
Senior Project Manager

1.0 INTRODUCTION

This survey was performed at the request of Mr. David Pomerantz, Director of the City of Northampton Central Services for the purpose of identifying regulated building materials that may impact the future renovations of the James' House, located on 42 Gothic Street in Northampton, Massachusetts. The Occupational Safety and Health Administration (OSHA) regulations (1926.1101 and 1926.62) require that building owners determine the presence and location of asbestos materials and convey that information to any individuals who will conduct work that may disturb said ACM. The Scope of Work included destructive identification and sampling of suspect materials within the above referenced building.

The building is a two story wood structure with an attic and stone basement. The building was primarily used as an office building and courthouse. The majority of building materials encountered were wood trusses, supports, gypsum board and plaster walls, and corrugated metal roofing with un-insulated deck. The building is heated by a radiant heat system with a centralized boiler room.

1.1 LIMITATIONS

The term "destructive sampling method" refers to the method of collecting samples that would require destruction of various building surfaces (i.e. wall cavities, wood flooring, plaster ceilings) for the purpose of locating hidden heating, plumbing, or other building components that may contain ACM. Destructive methods are strongly recommended for facilities slated for demolition.

Additional limitations may exist for destructive sampling methods. Certain portions of the building may be physically inaccessible, or because electrical, mechanical, structural, or other hazards exist in portions of the structure at the time of the survey.

The following areas were not included in the scope of work at the time of this survey:

- Within Functioning Electrical/HVAC Equipment
- Below Hardwood Floors
- Behind Clapboard Siding
- Below Grade
- Roofing

2.0 METHODS AND MATERIALS

2.1 ASBESTOS

Samples were collected in a statistically random manner using the Asbestos Hazard Emergency Response Act (AHERA) protocol (40 CFR 763.86). Samples were placed into plastic bags with an air tight seal. Labels were affixed to the sample bags with specific nomenclature.

Bulk samples were analyzed by Polarized Light Microscopy (PLM) using the United States Environmental Protection Agency USEPA/600/R-93/116 method. The analysis of samples was conducted by ProScience Analytical Services, Inc., 22 Cummings Park, Woburn, Massachusetts (NVLAP Accreditation 2000090-0).

There are six minerals grouped into the term "asbestos." Chrysotile, amosite, and crocidolite are the asbestos minerals most commonly found in building materials. ACM is defined as a material containing more than one percent (1%) asbestos by weight. Materials found to be asbestos containing are listed in Section 3.0. Exact sample compositions are included in the laboratory reports or chains of custody found in Appendix A.

Polarized light microscopy (PLM) is the root method used for the identification of ACM. The USEPA Office of Research and Development (USEPA/ORD) has reviewed data from performance audits of various laboratories performing PLM. The results of that review indicated an unacceptable number of false negatives and positives for visual estimation of materials containing less than 10% asbestos. On the basis of those findings the National Emissions Standards Hazardous Air Pollutants (NESHAP) regulations were amended on November 20, 1990 (Federal Register, V.55, N.224). The revisions state that if the analyst detects asbestos in the sample and estimates the amount to be less than 10% by visual estimation, the parties legally responsible (owner or operator) for the building may (1) elect to assume the amount to be greater than 1% and treat the material as ACM or (2) require verification of the amount by point counting. Point counting is a technique used to quantify the amount of asbestos present in a sample on which PLM has already been performed. ECS recommends point counting re-analysis for asbestos values less than 10%, and where applicable those results are reflected in the report. In instances where client authorization is not received for this reanalysis, PLM visual results indicating a trace or 1% value will be reported as assumed ACM as required by item (1) above.

A similar situation exists for matrix bound fibers such as those found in floor tiles, mastics, and asphalt based materials. The inorganic matrix of these bulk samples may interfere with the identification and quantification of asbestos mineral content. These types of samples are generally referred to as Non-organically bound (NOB) materials. Transmission Electron Microscopy (TEM-NOB) is a method that utilizes a combination of special sample preparation techniques and high magnification to more accurately quantify asbestos content. Currently only the State of New York has regulations requiring TEM-NOB re-analysis of suspect ACM for which negative or trace determination resulted from PLM analysis. Although additional cost is involved, ECS recommends TEM-NOB analysis under certain circumstances, as a state of the art means of evaluation.

3.0 RESULTS AND FINDINGS

The results of this inspection are presented in tabular form. These tables summarize the nature, distribution, and quantity of ACM identified during this survey.

Types, locations, quantities, and conditions of ACM are shown on Table 3.1. Suspect materials sampled and found not to contain ACM are found in Table 3.2.

| Functional Space (s) | Sample Number | Sample Location | Material Description | Material Class | Friability | Estimated Quantity |
|--|---------------|-----------------|------------------------|----------------|-------------|--------------------|
| Attic | 19A | Attic | Brown 9"x9" Floor Tile | Misc. | Non-Friable | 200 SF |
| Key: SF - Square Feet; Misc.- Miscellaneous | | | | | | |
| NOTES: See Limitations Section for areas deemed inaccessible or not included in Scope of Work | | | | | | |

TABLE 3.2
SUSPECT MATERIALS WITH NO ASBESTOS DETECTED
THE JAMES' HOUSE
42 GOTHIC STREET
NORTHAMPTON, MASSACHUSETTS

| Functional Space (s) | Material Description | Sample Number |
|--|--|---------------|
| Throughout | White Gypsum Board | 01A, 01B, 01C |
| Throughout | White Joint Compound | 02A, 02B, 02C |
| Throughout | Gray and White Plaster | 03A, 03B, 03C |
| Throughout | White 2'x2'/2'x4' Ceiling Tile with Holes and Fissures | 04A, 04B, 04C |
| Throughout | White 2'x2'/2'x4' Cratered Ceiling Tile | 05A, 05B, 05C |
| Boiler Room | Gray Flue Packing Insulation | 06A, 06B, 06C |
| Attic | Gray Deck Insulation | 07A, 07B, 07C |
| Courthouse Lobby | White Flooring Levelastic | 08A, 08B, 08C |
| Courthouse Stairwells | Black Mastic associated with Rubber Stair Tread Material | 09A, 09B |
| Courthouse | White/Grey Flecks 12"x12" Floor Tile | 10A |
| Courthouse | Yellow Mastic associated with White/Grey Flecks 12"x12" Floor Tile | 11A |
| Courthouse | Grey 12"x12" Floor Tile | 12A |
| Courthouse | Yellow Mastic associate with Grey 12"x12" Floor Tile | 13A |
| Courthouse | Red/Brown Levelastic under Sample 13A | 14A |
| Courthouse | Brown/White Flecks 12"x12" Floor Tile | 15A |
| Courthouse | Brown Mastic associated with Brown/White Flecks 12"x12" Floor Tile | 16A |
| Courthouse | Tan 12"x12" Floor Tile | 17A |
| Courthouse | Black Mastic associated with Tan 12"x12" Floor Tile | 18A |
| James' House – Attic | Black Mastic associated with Brown 9"x9" Floor Tile | 20A |
| Courthouse | Yellow Ceramic Tile Mastic | 21A |
| James' House | Beige Mastic associated with 4" White Vinyl Baseboard | 22A |
| Throughout | Beige Mastic associated 4" Blue Vinyl Baseboard | 23A, 23B |
| Courthouse | Beige Mastic associated with 4" Tan Vinyl Baseboard | 24A |
| Courthouse | Yellow Mastic associated with 4" Gray Vinyl Baseboard | 25A |
| Throughout | Yellow Mastic associated with Carpets | 26A, 26B |
| James' House | White Sink Soundproofing | 27A |
| Throughout | Black/Brown Paper Backing under 12"x12" Floor Tile | 28A |
| Courthouse | Gray Window Casing Caulking | 29A, 29B |
| NOTES: See Limitations Section for areas deemed inaccessible or not included in Scope of Work | | |

4.0 DISCUSSION AND INTERPRETATION

4.1 ASBESTOS

Response actions are based in-part upon our current understanding of area usage or future usage at the time of the survey. Removal is always indicated where pending renovation would disturb ACM. If ACM are not scheduled for removal they may be managed in-place through an Operations and Maintenance Plan. Any material discovered in the course of renovation activities which is not identified in this report should be presumed to contain asbestos until sampling shows otherwise. Section 1.1 Limitations details areas that were deemed inaccessible or were not included in the scope of work.

Tables 3.1 and 3.2 detail locations and results of all samples collected.

APPENDIX A

Laboratory Data

01-999999.99
 Job #: James' house
 Location: 42 Gothic St
 Northampton MA



588 Silver Street
 Agawam, Massachusetts 01001
 Ph: 413.789.3530 Fax: 413.789.2776

Page 1 of 10

| SAMPLE NUMBER | | COLOR | | SIZE | | MATERIAL | | |
|--------------------|--------------|----------|--------------------|---------------|-------------------|--------------------|--------------|----------|
| 01 | | Black | White | 9"x9" | Joint Compound | | | |
| | | Red | Blue | 12"x12" | Gypsum Board | | | |
| | | Yellow | Green | 1'x1' | Pipe Insulation | | | |
| | | Gray | Brown | 1'x2' | Duct Insulation | | | |
| | | Tan | Beige | 2'x2' | Skim Coat Plaster | | | |
| | | orange | Cream | 2'x4' | Basecoat Plaster | | | |
| Other: | | | Other: | Glue Daub | | | | |
| Other: | | | Other: | Fire Proofing | | | | |
| Other: | | | Other: | Other: | | | | |
| Sample ID | Floor: | Room: | Sample ID | Floor: | Room: | Sample ID | Floor: | Room: |
| A | Basement | Kitchen | B | Basement | Kitchen | C | Basement | Kitchen |
| | Ground Floor | Bathroom | | Ground Floor | Bathroom | | Ground Floor | Bathroom |
| | 1st Floor | Hallway | | 1st Floor | Hallway | | 1st Floor | Hallway |
| | 2nd Floor | Office | | 2nd Floor | Office | | 2nd Floor | Office |
| | 3rd Floor | Storage | | 3rd Floor | Storage | | 3rd Floor | Storage |
| | Other: | Other: | | Other: | Other: | | Other: | Other: |
| Comments: Court | | | Comments: Court | | | Comments: JAMES | | |

| SAMPLE NUMBER | | COLOR | | SIZE | | MATERIAL | | |
|--------------------|--------------|----------|--------------------|---------------|-------------------|--------------------|--------------|----------|
| 02 | | Black | White | 9"x9" | Joint Compound | | | |
| | | Red | Blue | 12"x12" | Gypsum Board | | | |
| | | Yellow | Green | 1'x1' | Pipe Insulation | | | |
| | | Gray | Brown | 1'x2' | Duct Insulation | | | |
| | | Tan | Beige | 2'x2' | Skim Coat Plaster | | | |
| | | orange | Cream | 2'x4' | Basecoat Plaster | | | |
| Other: | | | Other: | Glue Daub | | | | |
| Other: | | | Other: | Fire Proofing | | | | |
| Other: | | | Other: | Other: | | | | |
| Sample ID | Floor: | Room: | Sample ID | Floor: | Room: | Sample ID | Floor: | Room: |
| A | Basement | Kitchen | B | Basement | Kitchen | C | Basement | Kitchen |
| | Ground Floor | Bathroom | | Ground Floor | Bathroom | | Ground Floor | Bathroom |
| | 1st Floor | Hallway | | 1st Floor | Hallway | | 1st Floor | Hallway |
| | 2nd Floor | Office | | 2nd Floor | Office | | 2nd Floor | Office |
| | 3rd Floor | Storage | | 3rd Floor | Storage | | 3rd Floor | Storage |
| | Other: | Other: | | Other: | Other: | | Other: | Other: |
| Comments: Court | | | Comments: JAMES | | | Comments: JAMES | | |

Notes to Laboratory:

Inspector Name/Number: Christopher A. Coelho/ AI072176

Relinquished by/date: Christopher A. Coelho 1/20/09 Analysis: PLM

Received by/date: Kathy Artone 1-21-09 Turn Around Time: 4-5 days

10:20AM

49 samples

| SAMPLE NUMBER | | COLOR | | SIZE | | MATERIAL | | |
|-----------------------|--------------|----------|-----------------------|--------------|-------------------|-----------------------|----------------------|----------|
| 03 | | Black | White | 9"x9" | Joint Compound | Floor Tile | Cove Base | |
| | | Red | Blue | 12"x12" | Gypsum Board | Mastic | Ceiling Tile | |
| | | Yellow | Green | 1'x1' | Pipe Insulation | Caulking | Deck Insulation | |
| | | Gray | Brown | 1'x2' | Duct Insulation | Glazing | Breaching Insulation | |
| | | Tan | Beige | 2'x2' | Skim Coat Plaster | Cement Board | Roofing Tar | |
| | | orange | Cream | 2'x4' | Basecoat Plaster | Linoleum Backing | | |
| | | Other: | Other: | Other: | Glue Daub | Fire Proofing | | |
| Other: | | | Other: | | | | | |
| Sample ID | Floor: | Room: | Sample ID | Floor: | Room: | Sample ID | Floor: | Room: |
| A | Basement | Kitchen | B | Basement | Kitchen | C | Basement | Kitchen |
| | Ground Floor | Bathroom | | Ground Floor | Bathroom | | Ground Floor | Bathroom |
| | 1st Floor | Hallway | | 1st Floor | Hallway | | 1st Floor | Hallway |
| | 2nd Floor | Office | | 2nd Floor | Office | | 2nd Floor | Office |
| | 3rd Floor | Storage | | 3rd Floor | Storage | | 3rd Floor | Storage |
| | Other: | Other: | | Other: | Other: | | Other: | Other: |
| Comments: James house | | | Comments: James house | | | Comments: James house | | |

| SAMPLE NUMBER | | COLOR | | SIZE | | MATERIAL | | |
|-----------------|------------------|----------|-----------------|--------------|-------------------|------------------|----------------------|----------|
| 04 | | Black | White | 9"x9" | Joint Compound | Floor Tile | Cove Base | |
| | | Red | Blue | 12"x12" | Gypsum Board | Mastic | Ceiling Tile | |
| | | Yellow | Green | 1'x1' | Pipe Insulation | Caulking | Deck Insulation | |
| | | Gray | Brown | 1'x2' | Duct Insulation | Glazing | Breaching Insulation | |
| | | Tan | Beige | 2'x2' | Skim Coat Plaster | Cement Board | Roofing Tar | |
| | | orange | Cream | 2'x4' | Basecoat Plaster | Linoleum Backing | | |
| | | Other: | Other: | Other: | Glue Daub | Fire Proofing | | |
| Other: | holes & fissures | | Other: | | | | | |
| Sample ID | Floor: | Room: | Sample ID | Floor: | Room: | Sample ID | Floor: | Room: |
| A | Basement | Kitchen | B | Basement | Kitchen | C | Basement | Kitchen |
| | Ground Floor | Bathroom | | Ground Floor | Bathroom | | Ground Floor | Bathroom |
| | 1st Floor | Hallway | | 1st Floor | Hallway | | 1st Floor | Hallway |
| | 2nd Floor | Office | | 2nd Floor | Office | | 2nd Floor | Office |
| | 3rd Floor | Storage | | 3rd Floor | Storage | | 3rd Floor | Storage |
| | Other: | Other: | | Other: | Other: | | Other: | Other: |
| Comments: Court | | | Comments: James | | | Comments: James | | |

| SAMPLE NUMBER | | COLOR | | SIZE | | MATERIAL | | |
|-----------------|--------------|----------|-----------------------|--------------|-------------------|------------------|----------------------|----------|
| 05 | | Black | White | 9"x9" | Joint Compound | Floor Tile | Cove Base | |
| | | Red | Blue | 12"x12" | Gypsum Board | Mastic | Ceiling Tile | |
| | | Yellow | Green | 1'x1' | Pipe Insulation | Caulking | Deck Insulation | |
| | | Gray | Brown | 1'x2' | Duct Insulation | Glazing | Breaching Insulation | |
| | | Tan | Beige | 2'x2' | Skim Coat Plaster | Cement Board | Roofing Tar | |
| | | orange | Cream | 2'x4' | Basecoat Plaster | Linoleum Backing | | |
| | | Other: | Other: | Other: | Glue Daub | Fire Proofing | | |
| Other: | cracked | | Other: | | | | | |
| Sample ID | Floor: | Room: | Sample ID | Floor: | Room: | Sample ID | Floor: | Room: |
| A | Basement | Kitchen | B | Basement | Kitchen | C | Basement | Kitchen |
| | Ground Floor | Bathroom | | Ground Floor | Bathroom | | Ground Floor | Bathroom |
| | 1st Floor | Hallway | | 1st Floor | Hallway | | 1st Floor | Hallway |
| | 2nd Floor | Office | | 2nd Floor | Office | | 2nd Floor | Office |
| | 3rd Floor | Storage | | 3rd Floor | Storage | | 3rd Floor | Storage |
| | Other: | Other: | | Other: | Other: | | Other: | Other: |
| Comments: Court | | | Comments: Court James | | | Comments: James | | |

| SAMPLE NUMBER | | COLOR | | SIZE | MATERIAL | | | |
|------------------------------|--------------|----------|-----------|-------------------------------|-------------------|------------------|----------------------|----------|
| 06 | | Black | White | 9"x9" | Joint Compound | Floor Tile | Cove Base | |
| | | Red | Blue | 12"x12" | Gypsum Board | Mastic | Ceiling Tile | |
| | | Yellow | Green | 1'x1' | Pipe Insulation | Caulking | Deck Insulation | |
| | | Gray | Brown | 1'x2' | Duct Insulation | Glazing | Breeching Insulation | |
| | | Tan | Beige | 2'x2' | Skim Coat Plaster | Cement Board | Roofing Tar | |
| | | Orange | Cream | 2'x4' | Basecoat Plaster | Linoleum Backing | | |
| | | Other: | Other: | Other: | Glue Daub | Fire Proofing | | |
| | | | | Other: <u>Fluo insulation</u> | | | | |
| Sample ID | Floor: | Room: | Sample ID | Floor: | Room: | Sample ID | Floor: | Room: |
| A | Basement | Kitchen | B | Basement | Kitchen | C | Basement | Kitchen |
| | Ground Floor | Bathroom | | Ground Floor | Bathroom | | Ground Floor | Bathroom |
| | 1st Floor | Hallway | | 1st Floor | Hallway | | 1st Floor | Hallway |
| | 2nd Floor | Office | | 2nd Floor | Office | | 2nd Floor | Office |
| | 3rd Floor | Storage | | 3rd Floor | Storage | | 3rd Floor | Storage |
| | Other: | Other: | | Other: | Other: | | Other: | Other: |
| Comments: <u>Boiler Room</u> | | | Comments: | | | Comments: | | |

| SAMPLE NUMBER | | COLOR | | SIZE | MATERIAL | | | |
|------------------------|--------------|----------|------------------------|-------------------------------|-------------------|------------------------|----------------------|----------|
| 07 | | Black | White | 9"x9" | Joint Compound | Floor Tile | Cove Base | |
| | | Red | Blue | 12"x12" | Gypsum Board | Mastic | Ceiling Tile | |
| | | Yellow | Green | 1'x1' | Pipe Insulation | Caulking | Deck Insulation | |
| | | Gray | Brown | 1'x2' | Duct Insulation | Glazing | Breeching Insulation | |
| | | Tan | Beige | 2'x2' | Skim Coat Plaster | Cement Board | Roofing Tar | |
| | | Orange | Cream | 2'x4' | Basecoat Plaster | Linoleum Backing | | |
| | | Other: | Other: | Other: | Glue Daub | Fire Proofing | | |
| | | | | Other: <u>Deck insulation</u> | | | | |
| Sample ID | Floor: | Room: | Sample ID | Floor: | Room: | Sample ID | Floor: | Room: |
| A | Basement | Kitchen | B | Basement | Kitchen | C | Basement | Kitchen |
| | Ground Floor | Bathroom | | Ground Floor | Bathroom | | Ground Floor | Bathroom |
| | 1st Floor | Hallway | | 1st Floor | Hallway | | 1st Floor | Hallway |
| | 2nd Floor | Office | | 2nd Floor | Office | | 2nd Floor | Office |
| | 3rd Floor | Storage | | 3rd Floor | Storage | | 3rd Floor | Storage |
| | Other: | Other: | | Other: | Other: | | Other: | Other: |
| Comments: <u>JAMES</u> | | | Comments: <u>JAMES</u> | | | Comments: <u>JAMES</u> | | |

| SAMPLE NUMBER | | COLOR | | SIZE | MATERIAL | | | |
|------------------------------|--------------|----------|-----------|-------------------------|-------------------|------------------|----------------------|----------|
| 08 | | Black | White | 9"x9" | Joint Compound | Floor Tile | Cove Base | |
| | | Red | Blue | 12"x12" | Gypsum Board | Mastic | Ceiling Tile | |
| | | Yellow | Green | 1'x1' | Pipe Insulation | Caulking | Deck Insulation | |
| | | Gray | Brown | 1'x2' | Duct Insulation | Glazing | Breeching Insulation | |
| | | Tan | Beige | 2'x2' | Skim Coat Plaster | Cement Board | Roofing Tar | |
| | | Orange | Cream | 2'x4' | Basecoat Plaster | Linoleum Backing | | |
| | | Other: | Other: | Other: | Glue Daub | Fire Proofing | | |
| | | | | Other: <u>Levohstic</u> | | | | |
| Sample ID | Floor: | Room: | Sample ID | Floor: | Room: | Sample ID | Floor: | Room: |
| A | Basement | Kitchen | B | Basement | Kitchen | C | Basement | Kitchen |
| | Ground Floor | Bathroom | | Ground Floor | Bathroom | | Ground Floor | Bathroom |
| | 1st Floor | Hallway | | 1st Floor | Hallway | | 1st Floor | Hallway |
| | 2nd Floor | Office | | 2nd Floor | Office | | 2nd Floor | Office |
| | 3rd Floor | Storage | | 3rd Floor | Storage | | 3rd Floor | Storage |
| | Other: | Other: | | Other: | Other: | | Other: | Other: |
| Comments: <u>Court Lobby</u> | | | Comments: | | | Comments: | | |

| SAMPLE NUMBER | | COLOR | | SIZE | | MATERIAL | | |
|----------------------------------|--------------|----------|----------------------------|--------------|----------|--------------------------------------|------------------|----------------------|
| 09 | | Black | White | 9"x9" | | Joint Compound | Floor Tile | Cove Base |
| | | Red | Blue | 12"x12" | | Gypsum Board | Mastic | Ceiling Tile |
| | | Yellow | Green | 1"x1' | | Pipe Insulation | Caulking | Deck Insulation |
| | | Gray | Brown | 1"x2' | | Duct Insulation | Glazing | Breaching Insulation |
| | | Tan | Beige | 2"x2' | | Skim Coat Plaster | Cement Board | Roofing Tar |
| | | orange | Cream | 2"x4' | | Basecoat Plaster | Linoleum Backing | |
| Other: | | | | Other: | | Glue Daub Fire Proofing Other: | | |
| Sample ID | Floor: | Room: | Sample ID | Floor: | Room: | Sample ID | Floor: | Room: |
| A | Basement | Kitchen | B | Basement | Kitchen | | Basement | Kitchen |
| | Ground Floor | Bathroom | | Ground Floor | Bathroom | | Ground Floor | Bathroom |
| | 1st Floor | Hallway | | 1st Floor | Hallway | | 1st Floor | Hallway |
| | 2nd Floor | Office | | 2nd Floor | Office | | 2nd Floor | Office |
| | 3rd Floor | Storage | | 3rd Floor | Storage | | 3rd Floor | Storage |
| | Other: | Other: | | Other: | Other: | | Other: | Other: |
| Comments: Court → Assw/Rubber | | | Comments: Stair tread → | | | Comments: | | |

| SAMPLE NUMBER | | COLOR | | SIZE | | MATERIAL | | |
|--------------------|--------------|---------------|-----------|--------------|----------|--------------------------------------|------------------|----------------------|
| 10 | | Black | White | 9"x9" | | Joint Compound | Floor Tile | Cove Base |
| | | Red | Blue | 12"x12" | | Gypsum Board | Mastic | Ceiling Tile |
| | | Yellow | Green | 1"x1' | | Pipe Insulation | Caulking | Deck Insulation |
| | | Gray | Brown | 1"x2' | | Duct Insulation | Glazing | Breaching Insulation |
| | | Tan | Beige | 2"x2' | | Skim Coat Plaster | Cement Board | Roofing Tar |
| | | orange | Cream | 2"x4' | | Basecoat Plaster | Linoleum Backing | |
| Other: | | w/Gray Flecks | | Other: | | Glue Daub Fire Proofing Other: | | |
| Sample ID | Floor: | Room: | Sample ID | Floor: | Room: | Sample ID | Floor: | Room: |
| A | Basement | Kitchen | | Basement | Kitchen | | Basement | Kitchen |
| | Ground Floor | Bathroom | | Ground Floor | Bathroom | | Ground Floor | Bathroom |
| | 1st Floor | Hallway | | 1st Floor | Hallway | | 1st Floor | Hallway |
| | 2nd Floor | Office | | 2nd Floor | Office | | 2nd Floor | Office |
| | 3rd Floor | Storage | | 3rd Floor | Storage | | 3rd Floor | Storage |
| | Other: | Other: | | Other: | Other: | | Other: | Other: |
| Comments: Court | | | Comments: | | | Comments: | | |

| SAMPLE NUMBER | | COLOR | | SIZE | | MATERIAL | | |
|-----------------------|--------------|----------|-----------|--------------|----------|--------------------------------------|------------------|----------------------|
| 11 | | Black | White | 9"x9" | | Joint Compound | Floor Tile | Cove Base |
| | | Red | Blue | 12"x12" | | Gypsum Board | Mastic | Ceiling Tile |
| | | Yellow | Green | 1"x1' | | Pipe Insulation | Caulking | Deck Insulation |
| | | Gray | Brown | 1"x2' | | Duct Insulation | Glazing | Breaching Insulation |
| | | Tan | Beige | 2"x2' | | Skim Coat Plaster | Cement Board | Roofing Tar |
| | | orange | Cream | 2"x4' | | Basecoat Plaster | Linoleum Backing | |
| Other: | | | | Other: | | Glue Daub Fire Proofing Other: | | |
| Sample ID | Floor: | Room: | Sample ID | Floor: | Room: | Sample ID | Floor: | Room: |
| A | Basement | Kitchen | | Basement | Kitchen | | Basement | Kitchen |
| | Ground Floor | Bathroom | | Ground Floor | Bathroom | | Ground Floor | Bathroom |
| | 1st Floor | Hallway | | 1st Floor | Hallway | | 1st Floor | Hallway |
| | 2nd Floor | Office | | 2nd Floor | Office | | 2nd Floor | Office |
| | 3rd Floor | Storage | | 3rd Floor | Storage | | 3rd Floor | Storage |
| | Other: | Other: | | Other: | Other: | | Other: | Other: |
| Comments: Assw/10A | | | Comments: | | | Comments: | | |

| SAMPLE NUMBER | | COLOR | | SIZE | | MATERIAL | | |
|--------------------|--------------|----------|-----------|---------------|--|------------------|----------------------|----------|
| 12 | | Black | White | 9"x9" | Joint Compound Gypsum Board Pipe Insulation Duct Insulation Skim Coat Plaster Basecoat Plaster Glue Daub Other: | Floor Tile | Cove Base | |
| | | Red | Blue | 12"x12" | | Mastic | Ceiling Tile | |
| | | Yellow | Green | 1'x1' | | Caulking | Deck Insulation | |
| | | Gray | Brown | 1'x2' | | Glazing | Breeching Insulation | |
| | | Tan | Beige | 2'x2' | | Cement Board | Roofing Tar | |
| | | orange | Cream | 2'x4' | | Linoleum Backing | | |
| Other: | | Other: | | Fire Proofing | | | | |
| Sample ID | Floor: | Room: | Sample ID | Floor: | Room: | Sample ID | Floor: | Room: |
| A | Basement | Kitchen | | Basement | Kitchen | | Basement | Kitchen |
| | Ground Floor | Bathroom | | Ground Floor | Bathroom | | Ground Floor | Bathroom |
| | 1st Floor | Hallway | | 1st Floor | Hallway | | 1st Floor | Hallway |
| | 2nd Floor | Office | | 2nd Floor | Office | | 2nd Floor | Office |
| | 3rd Floor | Storage | | 3rd Floor | Storage | | 3rd Floor | Storage |
| | Other: | Other: | | Other: | Other: | | Other: | Other: |
| Comments: Court | | | Comments: | | | Comments: | | |

| SAMPLE NUMBER | | COLOR | | SIZE | | MATERIAL | | |
|------------------------|--------------|----------|-----------|---------------|--|------------------|----------------------|----------|
| 13 | | Black | White | 9"x9" | Joint Compound Gypsum Board Pipe Insulation Duct Insulation Skim Coat Plaster Basecoat Plaster Glue Daub Other: | Floor Tile | Cove Base | |
| | | Red | Blue | 12"x12" | | Mastic | Ceiling Tile | |
| | | Yellow | Green | 1'x1' | | Caulking | Deck Insulation | |
| | | Gray | Brown | 1'x2' | | Glazing | Breeching Insulation | |
| | | Tan | Beige | 2'x2' | | Cement Board | Roofing Tar | |
| | | orange | Cream | 2'x4' | | Linoleum Backing | | |
| Other: | | Other: | | Fire Proofing | | | | |
| Sample ID | Floor: | Room: | Sample ID | Floor: | Room: | Sample ID | Floor: | Room: |
| A | Basement | Kitchen | | Basement | Kitchen | | Basement | Kitchen |
| | Ground Floor | Bathroom | | Ground Floor | Bathroom | | Ground Floor | Bathroom |
| | 1st Floor | Hallway | | 1st Floor | Hallway | | 1st Floor | Hallway |
| | 2nd Floor | Office | | 2nd Floor | Office | | 2nd Floor | Office |
| | 3rd Floor | Storage | | 3rd Floor | Storage | | 3rd Floor | Storage |
| | Other: | Other: | | Other: | Other: | | Other: | Other: |
| Comments: ASS w/12A | | | Comments: | | | Comments: | | |

| SAMPLE NUMBER | | COLOR | | SIZE | | MATERIAL | | |
|--------------------------------|--------------|----------|-----------|---------------|--|------------------|----------------------|----------|
| 14 | | Black | White | 9"x9" | Joint Compound Gypsum Board Pipe Insulation Duct Insulation Skim Coat Plaster Basecoat Plaster Glue Daub Other: Lowelstic | Floor Tile | Cove Base | |
| | | Red | Blue | 12"x12" | | Mastic | Ceiling Tile | |
| | | Yellow | Green | 1'x1' | | Caulking | Deck Insulation | |
| | | Gray | Brown | 1'x2' | | Glazing | Breeching Insulation | |
| | | Tan | Beige | 2'x2' | | Cement Board | Roofing Tar | |
| | | orange | Cream | 2'x4' | | Linoleum Backing | | |
| Other: | | Other: | | Fire Proofing | | | | |
| Sample ID | Floor: | Room: | Sample ID | Floor: | Room: | Sample ID | Floor: | Room: |
| A | Basement | Kitchen | | Basement | Kitchen | | Basement | Kitchen |
| | Ground Floor | Bathroom | | Ground Floor | Bathroom | | Ground Floor | Bathroom |
| | 1st Floor | Hallway | | 1st Floor | Hallway | | 1st Floor | Hallway |
| | 2nd Floor | Office | | 2nd Floor | Office | | 2nd Floor | Office |
| | 3rd Floor | Storage | | 3rd Floor | Storage | | 3rd Floor | Storage |
| | Other: | Other: | | Other: | Other: | | Other: | Other: |
| Comments: Court - under 13A | | | Comments: | | | Comments: | | |

| SAMPLE NUMBER | | COLOR | | SIZE | | MATERIAL | | |
|---------------|--------------|----------------|-----------|--------------|----------|-------------------|------------------|----------------------|
| 15 | | Black | White | 9"x9" | | Joint Compound | Floor Tile | Cove Base |
| | | Red | Blue | 12"x12" | | Gypsum Board | Mastic | Ceiling Tile |
| | | Yellow | Green | 1'x1' | | Pipe Insulation | Caulking | Deck Insulation |
| | | Gray | Brown | 1'x2' | | Duct Insulation | Glazing | Breeching Insulation |
| | | Tan | Beige | 2'x2' | | Skim Coat Plaster | Cement Board | Roofing Tar |
| | | Orange | Cream | 2'x4' | | Basecoat Plaster | Linoleum Backing | |
| Other: | | w/white flecks | | Other: | | Glue Daub | | Fire Proofing |
| Other: | | | | | | | | |
| Sample ID | Floor: | Room: | Sample ID | Floor: | Room: | Sample ID | Floor: | Room: |
| A | Basement | Kitchen | | Basement | Kitchen | | Basement | Kitchen |
| | Ground Floor | Bathroom | | Ground Floor | Bathroom | | Ground Floor | Bathroom |
| | 1st Floor | Hallway | | 1st Floor | Hallway | | 1st Floor | Hallway |
| | 2nd Floor | Office | | 2nd Floor | Office | | 2nd Floor | Office |
| | 3rd Floor | Storage | | 3rd Floor | Storage | | 3rd Floor | Storage |
| | Other: | Other: | | Other: | Other: | | Other: | Other: |
| Comments: | | | Comments: | | | Comments: | | |
| Landing | | | | | | | | |

| SAMPLE NUMBER | | COLOR | | SIZE | | MATERIAL | | |
|---------------------------------|--------------|----------|-----------|--------------|----------|-------------------|------------------|----------------------|
| 16 | | Black | White | 9"x9" | | Joint Compound | Floor Tile | Cove Base |
| | | Red | Blue | 12"x12" | | Gypsum Board | Mastic | Ceiling Tile |
| | | Yellow | Green | 1'x1' | | Pipe Insulation | Caulking | Deck Insulation |
| | | Gray | Brown | 1'x2' | | Duct Insulation | Glazing | Breeching Insulation |
| | | Tan | Beige | 2'x2' | | Skim Coat Plaster | Cement Board | Roofing Tar |
| | | Orange | Cream | 2'x4' | | Basecoat Plaster | Linoleum Backing | |
| Other: | | | | Other: | | Glue Daub | | Fire Proofing |
| Other: | | | | | | | | |
| Sample ID | Floor: | Room: | Sample ID | Floor: | Room: | Sample ID | Floor: | Room: |
| A | Basement | Kitchen | | Basement | Kitchen | | Basement | Kitchen |
| | Ground Floor | Bathroom | | Ground Floor | Bathroom | | Ground Floor | Bathroom |
| | 1st Floor | Hallway | | 1st Floor | Hallway | | 1st Floor | Hallway |
| | 2nd Floor | Office | | 2nd Floor | Office | | 2nd Floor | Office |
| | 3rd Floor | Storage | | 3rd Floor | Storage | | 3rd Floor | Storage |
| | Other: | Other: | | Other: | Other: | | Other: | Other: |
| Comments: | | | Comments: | | | Comments: | | |
| Ass w/ 15A & Rubber stair tread | | | | | | | | |

| SAMPLE NUMBER | | COLOR | | SIZE | | MATERIAL | | |
|---------------|--------------|----------|-----------|--------------|----------|-------------------|------------------|----------------------|
| 17 | | Black | White | 9"x9" | | Joint Compound | Floor Tile | Cove Base |
| | | Red | Blue | 12"x12" | | Gypsum Board | Mastic | Ceiling Tile |
| | | Yellow | Green | 1'x1' | | Pipe Insulation | Caulking | Deck Insulation |
| | | Gray | Brown | 1'x2' | | Duct Insulation | Glazing | Breeching Insulation |
| | | Tan | Beige | 2'x2' | | Skim Coat Plaster | Cement Board | Roofing Tar |
| | | Orange | Cream | 2'x4' | | Basecoat Plaster | Linoleum Backing | |
| Other: | | | | Other: | | Glue Daub | | Fire Proofing |
| Other: | | | | | | | | |
| Sample ID | Floor: | Room: | Sample ID | Floor: | Room: | Sample ID | Floor: | Room: |
| A | Basement | Kitchen | | Basement | Kitchen | | Basement | Kitchen |
| | Ground Floor | Bathroom | | Ground Floor | Bathroom | | Ground Floor | Bathroom |
| | 1st Floor | Hallway | | 1st Floor | Hallway | | 1st Floor | Hallway |
| | 2nd Floor | Office | | 2nd Floor | Office | | 2nd Floor | Office |
| | 3rd Floor | Storage | | 3rd Floor | Storage | | 3rd Floor | Storage |
| | Other: | Other: | | Other: | Other: | | Other: | Other: |
| Comments: | | | Comments: | | | Comments: | | |
| | | | | | | | | |

| SAMPLE NUMBER | | COLOR | | SIZE | | MATERIAL | | |
|---------------------|--------------|----------|-----------|--------------|----------|-------------------|------------------|----------------------|
| 18 | | Black | White | 9"x9" | | Joint Compound | Floor Tile | Cove Base |
| | | Red | Blue | 12"x12" | | Gypsum Board | Mastic | Ceiling Tile |
| | | Yellow | Green | 1'x1' | | Pipe Insulation | Caulking | Deck Insulation |
| | | Gray | Brown | 1'x2' | | Duct Insulation | Glazing | Breeching Insulation |
| | | Tan | Beige | 2'x2' | | Skim Coat Plaster | Cement Board | Roofing Tar |
| | | Orange | Cream | 2'x4' | | Basecoat Plaster | Linoleum Backing | |
| | | Other: | | Other: | | Glue Daub | Fire Proofing | |
| Other: | | | | | | | | |
| Sample ID | Floor: | Room: | Sample ID | Floor: | Room: | Sample ID | Floor: | Room: |
| A | Basement | Kitchen | | Basement | Kitchen | | Basement | Kitchen |
| | Ground Floor | Bathroom | | Ground Floor | Bathroom | | Ground Floor | Bathroom |
| | 1st Floor | Hallway | | 1st Floor | Hallway | | 1st Floor | Hallway |
| | 2nd Floor | Office | | 2nd Floor | Office | | 2nd Floor | Office |
| | 3rd Floor | Storage | | 3rd Floor | Storage | | 3rd Floor | Storage |
| | Other: | Other: | | Other: | Other: | | Other: | Other: |
| Comments: Ass w/17A | | | Comments: | | | Comments: | | |

| SAMPLE NUMBER | | COLOR | | SIZE | | MATERIAL | | |
|-------------------------|--------------|----------|-----------|--------------|----------|-------------------|------------------|----------------------|
| 19 | | Black | White | 9"x9" | | Joint Compound | Floor Tile | Cove Base |
| | | Red | Blue | 12"x12" | | Gypsum Board | Mastic | Ceiling Tile |
| | | Yellow | Green | 1'x1' | | Pipe Insulation | Caulking | Deck Insulation |
| | | Gray | Brown | 1'x2' | | Duct Insulation | Glazing | Breeching Insulation |
| | | Tan | Beige | 2'x2' | | Skim Coat Plaster | Cement Board | Roofing Tar |
| | | Orange | Cream | 2'x4' | | Basecoat Plaster | Linoleum Backing | |
| | | Other: | | Other: | | Glue Daub | Fire Proofing | |
| Other: | | | | | | | | |
| Sample ID | Floor: | Room: | Sample ID | Floor: | Room: | Sample ID | Floor: | Room: |
| A | Basement | Kitchen | | Basement | Kitchen | | Basement | Kitchen |
| | Ground Floor | Bathroom | | Ground Floor | Bathroom | | Ground Floor | Bathroom |
| | 1st Floor | Hallway | | 1st Floor | Hallway | | 1st Floor | Hallway |
| | 2nd Floor | Office | | 2nd Floor | Office | | 2nd Floor | Office |
| | 3rd Floor | Storage | | 3rd Floor | Storage | | 3rd Floor | Storage |
| | Other: | Other: | | Other: | Other: | | Other: | Other: |
| Comments: James 12'x15' | | | Comments: | | | Comments: | | |

| SAMPLE NUMBER | | COLOR | | SIZE | | MATERIAL | | |
|---------------------|--------------|----------|-----------|--------------|----------|-------------------|------------------|----------------------|
| 20 | | Black | White | 9"x9" | | Joint Compound | Floor Tile | Cove Base |
| | | Red | Blue | 12"x12" | | Gypsum Board | Mastic | Ceiling Tile |
| | | Yellow | Green | 1'x1' | | Pipe Insulation | Caulking | Deck Insulation |
| | | Gray | Brown | 1'x2' | | Duct Insulation | Glazing | Breeching Insulation |
| | | Tan | Beige | 2'x2' | | Skim Coat Plaster | Cement Board | Roofing Tar |
| | | Orange | Cream | 2'x4' | | Basecoat Plaster | Linoleum Backing | |
| | | Other: | | Other: | | Glue Daub | Fire Proofing | |
| Other: | | | | | | | | |
| Sample ID | Floor: | Room: | Sample ID | Floor: | Room: | Sample ID | Floor: | Room: |
| A | Basement | Kitchen | | Basement | Kitchen | | Basement | Kitchen |
| | Ground Floor | Bathroom | | Ground Floor | Bathroom | | Ground Floor | Bathroom |
| | 1st Floor | Hallway | | 1st Floor | Hallway | | 1st Floor | Hallway |
| | 2nd Floor | Office | | 2nd Floor | Office | | 2nd Floor | Office |
| | 3rd Floor | Storage | | 3rd Floor | Storage | | 3rd Floor | Storage |
| | Other: | Other: | | Other: | Other: | | Other: | Other: |
| Comments: Ass w/19A | | | Comments: | | | Comments: | | |

| SAMPLE NUMBER | | COLOR | | SIZE | | MATERIAL | | |
|---------------------------------------|--------------|-----------------|-----------|--------------|----------|--------------------------------------|------------------|----------------------|
| 21 | | Black | White | 9"x9" | | Joint Compound | Floor Tile | Cove Base |
| | | Red | Blue | 12"x12" | | Gypsum Board | <u>Mastic</u> | Ceiling Tile |
| | | <u>Yellow</u> | Green | 1'x1' | | Pipe Insulation | Caulking | Deck Insulation |
| | | Gray | Brown | 1'x2' | | Duct Insulation | Glazing | Breeching Insulation |
| | | Tan | Beige | 2'x2' | | Skim Coat Plaster | Cement Board | Roofing Tar |
| | | orange | Cream | 2'x4' | | Basecoat Plaster | Linoleum Backing | |
| Other: | | | | Other: | | Glue Daub Fire Proofing Other: | | |
| Sample ID | Floor: | Room: | Sample ID | Floor: | Room: | Sample ID | Floor: | Room: |
| A | Basement | Kitchen | | Basement | Kitchen | | Basement | Kitchen |
| | Ground Floor | <u>Bathroom</u> | | Ground Floor | Bathroom | | Ground Floor | Bathroom |
| | 1st Floor | Hallway | | 1st Floor | Hallway | | 1st Floor | Hallway |
| | 2nd Floor | Office | | 2nd Floor | Office | | 2nd Floor | Office |
| | 3rd Floor | Storage | | 3rd Floor | Storage | | 3rd Floor | Storage |
| | Other: | Other: | | Other: | Other: | | Other: | Other: |
| Comments: Court - Ass w/ ceramic tile | | | Comments: | | | Comments: | | |

| SAMPLE NUMBER | | COLOR | | SIZE | | MATERIAL | | |
|--------------------------------------|------------------|----------------|--------------|--------------|----------|--------------------------------------|------------------|----------------------|
| 22 | | Black | White | 9"x9" | | Joint Compound | Floor Tile | Cove Base |
| | | Red | Blue | 12"x12" | | Gypsum Board | <u>Mastic</u> | Ceiling Tile |
| | | Yellow | Green | 1'x1' | | Pipe Insulation | Caulking | Deck Insulation |
| | | Gray | Brown | 1'x2' | | Duct Insulation | Glazing | Breeching Insulation |
| | | Tan | <u>Beige</u> | 2'x2' | | Skim Coat Plaster | Cement Board | Roofing Tar |
| | | orange | Cream | 2'x4' | | Basecoat Plaster | Linoleum Backing | |
| Other: | | | | Other: | | Glue Daub Fire Proofing Other: | | |
| Sample ID | Floor: | Room: | Sample ID | Floor: | Room: | Sample ID | Floor: | Room: |
| A | Basement | Kitchen | | Basement | Kitchen | | Basement | Kitchen |
| | Ground Floor | Bathroom | | Ground Floor | Bathroom | | Ground Floor | Bathroom |
| | <u>1st Floor</u> | <u>Hallway</u> | | 1st Floor | Hallway | | 1st Floor | Hallway |
| | 2nd Floor | Office | | 2nd Floor | Office | | 2nd Floor | Office |
| | 3rd Floor | Storage | | 3rd Floor | Storage | | 3rd Floor | Storage |
| | Other: | Other: | | Other: | Other: | | Other: | Other: |
| Comments: JAMES - ASS w 4" white VBS | | | Comments: | | | Comments: | | |

| SAMPLE NUMBER | | COLOR | | SIZE | | MATERIAL | | |
|-------------------------------------|------------------|----------------|-------------------------------------|------------------|----------------|--------------------------------------|------------------|----------------------|
| 23 | | Black | White | 9"x9" | | Joint Compound | Floor Tile | Cove Base |
| | | Red | Blue | 12"x12" | | Gypsum Board | <u>Mastic</u> | Ceiling Tile |
| | | Yellow | Green | 1'x1' | | Pipe Insulation | Caulking | Deck Insulation |
| | | Gray | Brown | 1'x2' | | Duct Insulation | Glazing | Breeching Insulation |
| | | Tan | <u>Beige</u> | 2'x2' | | Skim Coat Plaster | Cement Board | Roofing Tar |
| | | orange | Cream | 2'x4' | | Basecoat Plaster | Linoleum Backing | |
| Other: | | | | Other: | | Glue Daub Fire Proofing Other: | | |
| Sample ID | Floor: | Room: | Sample ID | Floor: | Room: | Sample ID | Floor: | Room: |
| A | Basement | Kitchen | | Basement | Kitchen | | Basement | Kitchen |
| | Ground Floor | Bathroom | | Ground Floor | Bathroom | | Ground Floor | Bathroom |
| | <u>1st Floor</u> | <u>Hallway</u> | | <u>1st Floor</u> | <u>Hallway</u> | | 1st Floor | Hallway |
| | 2nd Floor | Office | | 2nd Floor | Office | | 2nd Floor | Office |
| | 3rd Floor | Storage | | 3rd Floor | Storage | | 3rd Floor | Storage |
| | Other: | Other: | | Other: | Other: | | Other: | Other: |
| Comments: Court - ASS w 4" Blue VBS | | | Comments: JAMES - ASS w 4" Blue VBS | | | Comments: | | |

| SAMPLE NUMBER | | COLOR | | SIZE | | MATERIAL | | |
|--------------------------------------|--------------|----------|-----------|--------------|----------|-------------------|------------------|----------------------|
| 24 | | Black | White | 9"x9" | | Joint Compound | Floor Tile | Cove Base |
| | | Red | Blue | 12"x12" | | Gypsum Board | Mastic | Ceiling Tile |
| | | Yellow | Green | 1'x1' | | Pipe Insulation | Caulking | Deck Insulation |
| | | Gray | Brown | 1'x2' | | Duct Insulation | Glazing | Breaching Insulation |
| | | Tan | Beige | 2'x2' | | Skim Coat Plaster | Cement Board | Roofing Tar |
| | | orange | Cream | 2'x4' | | Basecoat Plaster | Linoleum Backing | |
| | | Other: | | Other: | | Glue Daub | Fire Proofing | |
| Other: | | | | | | | | |
| Sample ID | Floor: | Room: | Sample ID | Floor: | Room: | Sample ID | Floor: | Room: |
| A | Basement | Kitchen | | Basement | Kitchen | | Basement | Kitchen |
| | Ground Floor | Bathroom | | Ground Floor | Bathroom | | Ground Floor | Bathroom |
| | 1st Floor | Hallway | | 1st Floor | Hallway | | 1st Floor | Hallway |
| | 2nd Floor | Office | | 2nd Floor | Office | | 2nd Floor | Office |
| | 3rd Floor | Storage | | 3rd Floor | Storage | | 3rd Floor | Storage |
| | Other: | Other: | | Other: | Other: | | Other: | Other: |
| Comments: Court - Assw 44 tan VBB | | | Comments: | | | Comments: | | |

| SAMPLE NUMBER | | COLOR | | SIZE | | MATERIAL | | |
|-------------------------------------|--------------|----------|-----------|--------------|----------|-------------------|------------------|----------------------|
| 25 | | Black | White | 9"x9" | | Joint Compound | Floor Tile | Cove Base |
| | | Red | Blue | 12"x12" | | Gypsum Board | Mastic | Ceiling Tile |
| | | Yellow | Green | 1'x1' | | Pipe Insulation | Caulking | Deck Insulation |
| | | Gray | Brown | 1'x2' | | Duct Insulation | Glazing | Breaching Insulation |
| | | Tan | Beige | 2'x2' | | Skim Coat Plaster | Cement Board | Roofing Tar |
| | | orange | Cream | 2'x4' | | Basecoat Plaster | Linoleum Backing | |
| | | Other: | | Other: | | Glue Daub | Fire Proofing | |
| Other: | | | | | | | | |
| Sample ID | Floor: | Room: | Sample ID | Floor: | Room: | Sample ID | Floor: | Room: |
| A | Basement | Kitchen | | Basement | Kitchen | | Basement | Kitchen |
| | Ground Floor | Bathroom | | Ground Floor | Bathroom | | Ground Floor | Bathroom |
| | 1st Floor | Hallway | | 1st Floor | Hallway | | 1st Floor | Hallway |
| | 2nd Floor | Office | | 2nd Floor | Office | | 2nd Floor | Office |
| | 3rd Floor | Storage | | 3rd Floor | Storage | | 3rd Floor | Storage |
| | Other: | Other: | | Other: | Other: | | Other: | Other: |
| Comments: Court Assw 44 Gray VBB | | | Comments: | | | Comments: | | |

| SAMPLE NUMBER | | COLOR | | SIZE | | MATERIAL | | |
|-----------------------------|--------------|----------|-----------------------------|--------------|----------|-------------------|------------------|----------------------|
| 26 | | Black | White | 9"x9" | | Joint Compound | Floor Tile | Cove Base |
| | | Red | Blue | 12"x12" | | Gypsum Board | Mastic | Ceiling Tile |
| | | Yellow | Green | 1'x1' | | Pipe Insulation | Caulking | Deck Insulation |
| | | Gray | Brown | 1'x2' | | Duct Insulation | Glazing | Breaching Insulation |
| | | Tan | Beige | 2'x2' | | Skim Coat Plaster | Cement Board | Roofing Tar |
| | | orange | Cream | 2'x4' | | Basecoat Plaster | Linoleum Backing | |
| | | Other: | | Other: | | Glue Daub | Fire Proofing | |
| Other: | | | | | | | | |
| Sample ID | Floor: | Room: | Sample ID | Floor: | Room: | Sample ID | Floor: | Room: |
| A | Basement | Kitchen | | Basement | Kitchen | | Basement | Kitchen |
| | Ground Floor | Bathroom | | Ground Floor | Bathroom | | Ground Floor | Bathroom |
| | 1st Floor | Hallway | | 1st Floor | Hallway | | 1st Floor | Hallway |
| | 2nd Floor | Office | | 2nd Floor | Office | | 2nd Floor | Office |
| | 3rd Floor | Storage | | 3rd Floor | Storage | | 3rd Floor | Storage |
| | Other: | Other: | | Other: | Other: | | Other: | Other: |
| Comments: Court - Carpet | | | Comments: James - Carpet | | | Comments: | | |

| SAMPLE NUMBER | | COLOR | | SIZE | | MATERIAL | | |
|------------------------------------|--------------|----------|-----------|--------------|----------|-------------------|------------------|----------------------|
| 27 | | Black | White | 9"x9" | | Joint Compound | Floor Tile | Cove Base |
| | | Red | Blue | 12"x12" | | Gypsum Board | Mastic | Ceiling Tile |
| | | Yellow | Green | 1'x1' | | Pipe Insulation | Caulking | Deck Insulation |
| | | Gray | Brown | 1'x2' | | Duct Insulation | Glazing | Breaching Insulation |
| | | Tan | Beige | 2'x2' | | Skim Coat Plaster | Cement Board | Roofing Tar |
| | | orange | Cream | 2'x4' | | Basecoat Plaster | Linoleum Backing | |
| | | Other: | | Other: | | Glue Daub | Fire Proofing | |
| Other: <u>SOUNDPROOFING - SINK</u> | | | | | | | | |
| Sample ID | Floor: | Room: | Sample ID | Floor: | Room: | Sample ID | Floor: | Room: |
| A | Basement | Kitchen | | Basement | Kitchen | | Basement | Kitchen |
| | Ground Floor | Bathroom | | Ground Floor | Bathroom | | Ground Floor | Bathroom |
| | 1st Floor | Hallway | | 1st Floor | Hallway | | 1st Floor | Hallway |
| | 2nd Floor | Office | | 2nd Floor | Office | | 2nd Floor | Office |
| | 3rd Floor | Storage | | 3rd Floor | Storage | | 3rd Floor | Storage |
| | Other: | Other: | | Other: | Other: | | Other: | Other: |
| Comments: | | | Comments: | | | Comments: | | |
| JAMES | | | | | | | | |

| SAMPLE NUMBER | | COLOR | | SIZE | | MATERIAL | | |
|-----------------------------|--------------|----------|-----------|--------------|----------|-------------------|------------------|----------------------|
| 28 | | Black | White | 9"x9" | | Joint Compound | Floor Tile | Cove Base |
| | | Red | Blue | 12"x12" | | Gypsum Board | Mastic | Ceiling Tile |
| | | Yellow | Green | 1'x1' | | Pipe Insulation | Caulking | Deck Insulation |
| | | Gray | Brown | 1'x2' | | Duct Insulation | Glazing | Breaching Insulation |
| | | Tan | Beige | 2'x2' | | Skim Coat Plaster | Cement Board | Roofing Tar |
| | | orange | Cream | 2'x4' | | Basecoat Plaster | Linoleum Backing | |
| | | Other: | | Other: | | Glue Daub | Fire Proofing | |
| Other: <u>PAPER BACKING</u> | | | | | | | | |
| Sample ID | Floor: | Room: | Sample ID | Floor: | Room: | Sample ID | Floor: | Room: |
| A | Basement | Kitchen | | Basement | Kitchen | | Basement | Kitchen |
| | Ground Floor | Bathroom | | Ground Floor | Bathroom | | Ground Floor | Bathroom |
| | 1st Floor | Hallway | | 1st Floor | Hallway | | 1st Floor | Hallway |
| | 2nd Floor | Office | | 2nd Floor | Office | | 2nd Floor | Office |
| | 3rd Floor | Storage | | 3rd Floor | Storage | | 3rd Floor | Storage |
| | Other: | Other: | | Other: | Other: | | Other: | Other: |
| Comments: | | | Comments: | | | Comments: | | |
| under 12x12 F.T. | | | | | | | | |

| SAMPLE NUMBER | | COLOR | | SIZE | | MATERIAL | | |
|---------------|--------------|----------|-----------|--------------|----------|-------------------|------------------|----------------------|
| 29 | | Black | White | 9"x9" | | Joint Compound | Floor Tile | Cove Base |
| | | Red | Blue | 12"x12" | | Gypsum Board | Mastic | Ceiling Tile |
| | | Yellow | Green | 1'x1' | | Pipe Insulation | Caulking | Deck Insulation |
| | | Gray | Brown | 1'x2' | | Duct Insulation | Glazing | Breaching Insulation |
| | | Tan | Beige | 2'x2' | | Skim Coat Plaster | Cement Board | Roofing Tar |
| | | orange | Cream | 2'x4' | | Basecoat Plaster | Linoleum Backing | |
| | | Other: | | Other: | | Glue Daub | Fire Proofing | |
| Other: | | | | | | | | |
| Sample ID | Floor: | Room: | Sample ID | Floor: | Room: | Sample ID | Floor: | Room: |
| A | Basement | Kitchen | B | Basement | Kitchen | | Basement | Kitchen |
| | Ground Floor | Bathroom | | Ground Floor | Bathroom | | Ground Floor | Bathroom |
| | 1st Floor | Hallway | | 1st Floor | Hallway | | 1st Floor | Hallway |
| | 2nd Floor | Office | | 2nd Floor | Office | | 2nd Floor | Office |
| | 3rd Floor | Storage | | 3rd Floor | Storage | | 3rd Floor | Storage |
| | Other: | Other: | | Other: | Other: | | Other: | Other: |
| Comments: | | | Comments: | | | Comments: | | |
| Court-WCC | | | Court-WCC | | | | | |

ProScience Analytical Services, Inc.

PLM Asbestos Chain of Custody Record

LABORATORY/HEADQUARTERS

22 Cummings Park, Woburn, MA 01801

T: 781-935-3212 F: 781-932-4857

LABORATORY SERVICES

683 North Mountain Rd., Newington, CT 06111

T: 860-953-1022 F: 860-953-1030



☐ RUSH

Turn Around Time Requested

☐ Same day ☐ 24 Hour ☐ 48 Hour ☒ 72 Hour ☐ 5 Days

Page 1 of 9

Client: Environmental Compliance Services, ECS

Address: Agawam 01-21162

Project Site & Number: 01-999999-99 James' House 42-60th St

Phone / FAX Number: 413-789-3530 / 413-789-2776 North Hampton, MA

Contact: Chris Coelho

Relinquished by/date:

Received by/date:

Samples received:

Faxed, E-mailed, Verbal by/date:

Stop on first positive: Yes

For Lab Use> Batch Number

Analyzed by/date:

RI

| Lab ID | Field ID Sampled date | Description / Location | % Asbestos | Color | Homogeneity | Texture | Frable | Morphology | Extinction | Sign of Elongation | Birefringence | Pleochroism | Asbestos Percentage (%) | Circle Type | Asbestos Percentage (%) | Chrysotile | Amosite | Crocidolite | Tremolite | Anthophyllite | Actinolite | Fiberglass | Mineral Wool | Cellulose | Hair | Synthetic | Other | Non Fibrous |
|--------|-----------------------|------------------------|------------|-------|-------------|----------|---------|------------|------------|--------------------|---------------|-------------|-------------------------|-------------|-------------------------|------------|---------|-------------|-----------|---------------|------------|------------|--------------|-----------|------|-----------|-------|-------------|
| | 01A | | 0.01% | White | Homogeneous | Granular | Brittle | Amorphous | Extinction | Sign of Elongation | Birefringence | Pleochroism | Asbestos Percentage (%) | Circle Type | Asbestos Percentage (%) | Chrysotile | Amosite | Crocidolite | Tremolite | Anthophyllite | Actinolite | Fiberglass | Mineral Wool | Cellulose | Hair | Synthetic | Other | Non Fibrous |
| | B | | 0.01% | White | Homogeneous | Granular | Brittle | Amorphous | Extinction | Sign of Elongation | Birefringence | Pleochroism | Asbestos Percentage (%) | Circle Type | Asbestos Percentage (%) | Chrysotile | Amosite | Crocidolite | Tremolite | Anthophyllite | Actinolite | Fiberglass | Mineral Wool | Cellulose | Hair | Synthetic | Other | Non Fibrous |
| | C | | 0.01% | White | Homogeneous | Granular | Brittle | Amorphous | Extinction | Sign of Elongation | Birefringence | Pleochroism | Asbestos Percentage (%) | Circle Type | Asbestos Percentage (%) | Chrysotile | Amosite | Crocidolite | Tremolite | Anthophyllite | Actinolite | Fiberglass | Mineral Wool | Cellulose | Hair | Synthetic | Other | Non Fibrous |
| | 02A | | 0.01% | White | Homogeneous | Granular | Brittle | Amorphous | Extinction | Sign of Elongation | Birefringence | Pleochroism | Asbestos Percentage (%) | Circle Type | Asbestos Percentage (%) | Chrysotile | Amosite | Crocidolite | Tremolite | Anthophyllite | Actinolite | Fiberglass | Mineral Wool | Cellulose | Hair | Synthetic | Other | Non Fibrous |
| | B | | 0.01% | White | Homogeneous | Granular | Brittle | Amorphous | Extinction | Sign of Elongation | Birefringence | Pleochroism | Asbestos Percentage (%) | Circle Type | Asbestos Percentage (%) | Chrysotile | Amosite | Crocidolite | Tremolite | Anthophyllite | Actinolite | Fiberglass | Mineral Wool | Cellulose | Hair | Synthetic | Other | Non Fibrous |
| | C | | 0.01% | White | Homogeneous | Granular | Brittle | Amorphous | Extinction | Sign of Elongation | Birefringence | Pleochroism | Asbestos Percentage (%) | Circle Type | Asbestos Percentage (%) | Chrysotile | Amosite | Crocidolite | Tremolite | Anthophyllite | Actinolite | Fiberglass | Mineral Wool | Cellulose | Hair | Synthetic | Other | Non Fibrous |

Comments:

Olympus BTHZ SN 229027

For complete information about our services and locations please visit us at www.proscience.net or call the numbers above.

ProScience Analytical Services, Inc.

PLM Asbestos Chain of Custody Record

LABORATORY/HEADQUARTERS
22 Cummings Park, Woburn, MA 01801
T: 781-935-3212 F: 781-932-4857

LABORATORY SERVICES
683 North Mountain Rd., Newington, CT 06111
T: 860-953-1022 F: 860-953-1030



☐ RUSH

Turn Around Time Requested

☐ Same day ☐ 24 Hour ☐ 48 Hour ☒ 72 Hour ☐ 5 Days

Client: Environmental Compliance Services, ECS
Address: Agawam
Project Site & Number: 01-999999-99 James House 42-60th St
Phone / FAX Number: 413-789-3530 / 413-789-2776
Contact: Chris Coelho
Relinquished by/date: KA Fato 9/10/04
Received by/date: 49 Analyzed:
Faxed, E-mailed, Verbal by/date:
Stop on first positive: Yes No

For Lab Use> Batch Number: 3 Analyzed by/date: 88/28/09 QC by/date:

| Lab ID | Field ID Sampled date | Description / Location | Stereo Scope | | | | Optical Properties | | | | | | RI | | Asbestos Percentage (%) | | | | | Non Asbestos Percentage (%) | | | | | | | |
|--------|-----------------------------|------------------------|--------------|-------|-------------|---------|--------------------|------------|------------|--------------------|---------------|-------------|----|---|-------------------------|---------|-------------|-----------|---------------|-----------------------------|------------|--------------|-----------|------|-----------|-------|-------------|
| | | | % Asbestos | Color | Homogeneity | Texture | Friable | Morphology | Extinction | Sign of Elongation | Birefringence | Pleochroism | | | Chrysotile | Amosite | Crocidolite | Tremolite | Anthophyllite | Actinolite | Fiberglass | Mineral Wool | Cellulose | Hair | Synthetic | Other | Non Fibrous |
| | 03A | | 0 | Gray | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| | B | | 0 | Gray | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| | C | | 0 | Gray | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| | 04A | | 0 | Gray | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| | B | | 0 | Gray | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| | C | | 0 | Gray | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Comments:

For complete information about our services and locations please visit us at www.proscience.net or call the numbers above.



☐ RUSH

Turn Around Time Requested

☐ Same day ☐ 24 Hour ☐ 48 Hour ☒ 72 Hour ☐ 5 Days

Client: Environmental Compliance Services, ECS

Address: Agawam

Project Site & Number: 01-999999-99 James House 4260 N. C. St.

Phone / FAX Number: 413-789-3530 / 413-789-2776 New Hampton, MA

Contact: Chris Coelho

Relinquished by/date:

Received by/date:

Samples received: 49 Analyzed: KA 10/09/00

Faxed, E-mailed, Verbal by/date:

Stop on first positive: Yes

For Lab Use> Batch Number: B

Analyzed by/date: SP 10/08/09

QC by/date:

| Lab ID | Field ID Sampled date | Description / Location | Stere Scope | | | | Optical Properties | | | | | RI | Asbestos Percentage (%) | | | | | Non Asbestos Percentage (%) | | | | | | | |
|--------|-----------------------------|------------------------|-------------|-------|-------------|---------|--------------------|------------|------------|--------------------|---------------|----|-------------------------|------------|---------|-------------|-----------|-----------------------------|------------|------------|--------------|-----------|------|-----------|-------|
| | | | % Asbestos | Color | Homogeneity | Texture | Friable | Morphology | Extinction | Sign of Elongation | Birefringence | | Pleochroism | Chrysotile | Amosite | Crocidolite | Tremolite | Anthophyllite | Actinolite | Fiberglass | Mineral Wool | Cellulose | Hair | Synthetic | Other |
| | 05A | | 0 TWPY | | | | | | | | | I | | | | | | | | 7/83 | 60/30 | | | | 10 |
| | B | | 0 TWPY | | | | | | | | | | | | | | | | | 7/83 | 60/30 | | | | 10 |
| | C | | 0 TWPY | | | | | | | | | | | | | | | | | 7/83 | 60/30 | | | | 10 |
| | 06A | | 0 GJWY | | | | | | | | | | | | | | | | | I | 40 | | | | 60 |
| | B | | 0 GJWY | | | | | | | | | | | | | | | | | I | 40 | | | | 60 |
| | C | | 0 GJWY | | | | | | | | | | | | | | | | | 7 | 40 | | | | 60 |

Comments:

For complete information about our services and locations please visit us at www.proscience.net or call the numbers above.

ProScience Analytical Services, Inc.

PLM Asbestos Chain of Custody Record

LABORATORY/HEADQUARTERS
22 Cummings Park, Woburn, MA 01801
T: 781-935-3212 F: 781-932-4857

Client: Environmental Compliance Services, ECS

Address: Agawam

Project Site & Number: 01-999999-99

Phone / FAX Number: 413-789-3530 / 413-789-2776

Contact: Chris Coelho

For Lab Use: Batch Number B

Analyzed by/date: DB/08-09

QC by/date:

| Lab ID | Field ID Sampled date | Description / Location | Stereo Scope | | | Optical Properties | | | | | | RI | Asbestos Percentage (%) | | | | | | Non Asbestos Percentage (%) | | | | | | |
|--------|-----------------------------|------------------------|--------------|-------|-------------|--------------------|----------|------------|------------|--------------------|---------------|----|-------------------------|------------|---------|-------------|-----------|---------------|-----------------------------|------------|--------------|-----------|------|-----------|-------|
| | | | % Asbestos | Color | Homogeneity | Texture | Fracture | Morphology | Extinction | Sign of Elongation | Birefringence | | Pleochroism | Chrysotile | Amosite | Crocidolite | Tremolite | Anthophyllite | Actinolite | Fiberglass | Mineral Wool | Cellulose | Hair | Synthetic | Other |
| | 07A | | 07A | | | | | | | | | 1 | | | | | | | | | 10 | | | | 2 |
| | B | | 07B | | | | | | | | | 1 | | | | | | | | | 10 | | | | 2 |
| | C | | 07C | | | | | | | | | 1 | | | | | | | | | 10 | | | | 2 |
| | 08A | | 08A | | | | | | | | | 1 | | | | | | | | | 10 | | | | 10 |
| | B | | 08B | | | | | | | | | 1 | | | | | | | | | 10 | | | | 10 |
| | C | | 08C | | | | | | | | | 1 | | | | | | | | | 10 | | | | 10 |

Comments:

For complete information about our services and locations please visit us at www.proscience.net or call the numbers above.

Revised on 7/20/07



☐ RUSH

Page 4 of 9

Turn Around Time Requested

☐ Same day ☐ 24 Hour ☐ 48 Hour ☒ 72 Hour ☐ 5 Days

Relinquished by/date:

Received by/date:

Samples received: 4/9

Faxed, E-mailed, Verbal by/date:

Stop on first positive: Yes

No

KA 10/09/100A

Analyzed:

ProScience Analytical Services, Inc.

PLM Asbestos Chain of Custody Record

LABORATORY/HEADQUARTERS

22 Cummings Park, Woburn, MA 01801
T: 781-935-3212 F: 781-932-4857

LABORATORY SERVICES

683 North Mountain Rd., Newington, CT 06111
T: 860-953-1022 F: 860-953-1030



☐ RUSH

Turn Around Time Requested

☐ Same day ☐ 24 Hour ☐ 48 Hour ☒ 72 Hour ☐ 5 Days

Client: Environmental Compliance Services, ECS

Address: Agawam

Project Site & Number: 01-999999-99

Phone / FAX Number: 413-789-3530 / 413-789-2776

Contact: Chris Coelho

Relinquished by/date:

Received by/date:

Samples received:

Faxed, E-mailed, Verbal by/date:

Stop on first positive: Yes

No

Analyzed by/date:

QC by/date:

For Lab Use > Batch Number

| Lab ID | | Field ID Sampled date | Description / Location | Stereoscopy | | | | Optical Properties | | | | RI | Asbestos Percentage (%) | | | | | Non Asbestos Percentage (%) | | | | | | | | | | |
|--------|--|-----------------------------|------------------------|-------------|-------------|-------------|---------|--------------------|------------|------------|--------------------|---------------|-------------------------|----|------------|---------|-------------|-----------------------------|---------------|------------|------------|--------------|-----------|------|-----------|-------|-------------|----|
| | | | | % Asbestos | Color | Homogeneity | Texture | Friable | Morphology | Extinction | Sign of Elongation | Birefringence | Pleochroism | | Chrysotile | Amosite | Crocidolite | Tremolite | Anthophyllite | Actinolite | Fiberglass | Mineral Wool | Cellulose | Hair | Synthetic | Other | Non Fibrous | |
| | | 09A | | 0 | Light Green | Homogeneous | Smooth | Not Friable | Amorphous | Extinction | Sign of Elongation | Birefringence | Pleochroism | II | T | ■ | ■ | ■ | ■ | ■ | ■ | | | | | | | 10 |
| | | B | | 0 | Light Green | Homogeneous | Smooth | Not Friable | Amorphous | Extinction | Sign of Elongation | Birefringence | Pleochroism | | ■ | ■ | ■ | ■ | ■ | ■ | ■ | | | | | | | 10 |
| | | 10A | | 0 | Light Green | Homogeneous | Smooth | Not Friable | Amorphous | Extinction | Sign of Elongation | Birefringence | Pleochroism | | ■ | ■ | ■ | ■ | ■ | ■ | ■ | | | | | | | 10 |
| | | 11A | | 0 | Light Green | Homogeneous | Smooth | Not Friable | Amorphous | Extinction | Sign of Elongation | Birefringence | Pleochroism | | ■ | ■ | ■ | ■ | ■ | ■ | ■ | | | | | | | 10 |
| | | 12A | | 0 | Light Green | Homogeneous | Smooth | Not Friable | Amorphous | Extinction | Sign of Elongation | Birefringence | Pleochroism | | ■ | ■ | ■ | ■ | ■ | ■ | ■ | | | | | | | 10 |
| | | 13A | | 0 | Light Green | Homogeneous | Smooth | Not Friable | Amorphous | Extinction | Sign of Elongation | Birefringence | Pleochroism | | ■ | ■ | ■ | ■ | ■ | ■ | ■ | | | | | | | 10 |

Comments:

For complete information about our services and locations please visit us at www.proscience.net or call the numbers above.

ProScience Analytical Services, Inc.

PLM Asbestos Chain of Custody Record

LABORATORY/HEADQUARTERS
22 Cummings Park, Woburn, MA 01801
T: 781-935-3212 F: 781-932-4857

LABORATORY SERVICES
683 North Mountain Rd., Newington, CT 06111
T: 860-953-1022 F: 860-953-1030



☐ RUSH

Turn Around Time Requested

☐ Same day ☐ 24 Hour ☐ 48 Hour ☒ 72 Hour ☐ 5 Days

Client: Environmental Compliance Services, ECS
Address: Agawam
Project Site & Number: 01-999999-99 James House 4260 N. Ct. KA 10709 1020A
Phone / FAX Number: 413-789-3530 / 413-789-2776 Northampton, MA 99 Analyzed:
Contact: Chris Coelho Faxed, E-mailed, Verbal by/date: Stop on first positive: Yes No
Relinquished by/date: Received by/date: QC by/date: 8/2/89

| For Lab Use> Batch Number | | | Analyzed by/date: 08/28/89 | | | | | | | | | | QC by/date: | | | | | | | | | | | | | |
|---------------------------|-----------------------------|------------------------|----------------------------|-------|-------------|--------------------|---------|------------|------------|--------------------|---------------|----|-------------------------|------------|---------|-------------|-----------|---------------|-----------------------------|------------|--------------|-----------|------|-----------|-------|-------------|
| Lab ID | Field ID Sampled date | Description / Location | Stereos Scope | | | Optical Properties | | | | | | RI | Asbestos Percentage (%) | | | | | | Non Asbestos Percentage (%) | | | | | | | |
| | | | % Asbestos | Color | Homogeneity | Texture | Friable | Morphology | Extinction | Sign of Elongation | Birefringence | | Pleochroism | Chrysotile | Amosite | Crocidolite | Tremolite | Anthophyllite | Actinolite | Fiberglass | Mineral Wool | Cellulose | Hair | Synthetic | Other | Non Fibrous |
| | 14A | | 0 RW | | | | | | | | | II | I | | | | | | | | the | | | | | 98 |
| | 15A | | 0 RW | | | | | | | | | | | | | | | | | | 2 | | | | | 10 |
| | 16A | | 0 RW | | | | | | | | | | | | | | | | | | | | | | | 10 |
| | 17A | | 0 RW | | | | | | | | | | | | | | | | | | | | | | | 10 |
| | 18A | | 0 RW | | | | | | | | | | | | | | | | | | 10 | | | | | 90 |
| | 19A | | 0 RW | | | | | | | | | | | | | | | | | | | | | | | 95 |

Comments:

For complete information about our services and locations please visit us at www.proscience.net or call the numbers above.

ProScience Analytical Services, Inc.

PLM Asbestos Chain of Custody Record

LABORATORY/HEADQUARTERS 22 Cummings Park, Woburn, MA 01801
 T: 781-935-3212 F: 781-932-4857

LABORATORY SERVICES 683 North Mountain Rd., Newington, CT 06111
 T: 860-953-1022 F: 860-953-1030



☐ RUSH

Turn Around Time Requested

☐ Same day ☐ 24 Hour ☐ 48 Hour ☒ 72 Hour ☐ 5 Days

Client: Environmental Compliance Services, ECS
 Address: Agawam
 Project Site & Number: 01-999999-99 James House 42-60 NHC St
 Phone / FAX Number: 413-789-3530 / 413-789-2776 North Hampton, MA
 Contact: CNIS Coelho
 Relinquished by/date: KA 10/09/2004
 Received by/date: 49 Analyzed:
 Faxed, E-mailed, Verbal by/date:
 Stop on first positive: Yes No
 Analyzed by/date: SB/2809 QC by/date:

| Lab ID | Field ID Sampled date | Description / Location | % Asbestos | Color | Homogeneity | Texture | Friable | Morphology | Extinction | Sign of Elongation | Birefringence | Pleochroism | | ┐ | Chrysotile | Circle Type | | | | | Fiberglass | Mineral Wool | Cellulose | Hair | Synthetic | Other | Non Fibrous |
|--------|-----------------------------|------------------------|------------|-------|-------------|---------|---------|------------|------------|--------------------|---------------|-------------|--|---|------------|-------------|-------------|-----------|---------------|------------|------------|--------------|-----------|------|-----------|-------|-------------|
| | | | | | | | | | | | | | | | | Amosite | Crocidolite | Tremolite | Anthophyllite | Actinolite | | | | | | | |
| | 20A | | 0 | gray | hom | smooth | + | fib | | | | | | | | | | | | | | 2 | | | | 98 | |
| | 21A | | 0 | gray | hom | smooth | + | fib | | | | | | | | | | | | | | | | | | 100 | |
| | 22A | | 0 | gray | hom | smooth | + | fib | | | | | | | | | | | | | | 2 | | | | 98 | |
| | 23A | | 0 | gray | hom | smooth | + | fib | | | | | | | | | | | | | | 2 | | | | 98 | |
| | B | | 0 | gray | hom | smooth | + | fib | | | | | | | | | | | | | | 2 | | | | 98 | |
| | 24A | | 0 | gray | hom | smooth | + | fib | | | | | | | | | | | | | | 2 | | | | 98 | |

Comments:

For complete information about our services and locations please visit us at www.proscience.net or call the numbers above.

ProScience Analytical Services, Inc.

PLM Asbestos Chain of Custody Record

LABORATORY HEADQUARTERS
22 Cummings Park, Woburn, MA 01801
T: 781-935-3212 F: 781-932-4857

LABORATORY SERVICES
683 North Mountain Rd., Newington, CT 06111
T: 860-953-1022 F: 860-953-1030

☐ RUSH



Turn Around Time Requested

☐ Same day ☐ 24 Hour ☐ 48 Hour ☒ 72 Hour ☐ 5 Days

Page 8 of 9

Client: Environmental Compliance Services, ECS

Address: Agawam

Project Site & Number: 01-000000-99 James House 4260 W. St.

Phone / FAX Number: 413-789-3530 / 413-789-2776 North Hampton, MA

Contact: Chris Coelho

Relinquished by/date:

Received by/date:

Samples received: 49 Analyzed: KA 10/10/97

Faxed, E-mailed, Verbal by/date:

Stop on first positive: Yes

No

Analyzed by/date: SB/08/99

QC by/date:

For Lab Use> Batch Number 13

| Lab ID | | Field ID Sampled date | Description / Location | Stereo Scope | | | | Optical Properties | | | | RI | Asbestos Percentage (%) | | | | | | Non Asbestos Percentage (%) | | | | | | | | | | |
|--------|--|-----------------------------|------------------------|--------------|-------|-------------|---------|--------------------|------------|------------|--------------------|---------------|-------------------------|--|----|------------|---------|-------------|-----------------------------|---------------|------------|------------|--------------|-----------|------|-----------|-------|-------------|----|
| | | | | % Asbestos | Color | Homogeneity | Texture | Friable | Morphology | Extinction | Sign of Elongation | Birefringence | Pleochroism | | | Chrysotile | Amosite | Crocidolite | Tremolite | Anthophyllite | Actinolite | Fiberglass | Mineral Wool | Cellulose | Hair | Synthetic | Other | Non Fibrous | |
| | | 25A | | 0 ywsu | | | | | | | | | | | II | | | | | | | | | 100 | 2 | | | | 98 |
| | | 26A | | 0 ywsu | | | | | | | | | | | | | | | | | | | | 100 | 2 | | | | 98 |
| | | B | | 0 ywsu | | | | | | | | | | | | | | | | | | | | 100 | 2 | | | | 98 |
| | | 27A | | 0 wwsu | | | | | | | | | | | | | | | | | | | | 100 | 5 | | | | 95 |
| | | 28A | | 0 ywsu | | | | | | | | | | | | | | | | | | | | 100 | 50 | | | | 50 |
| | | 29A | | 0 ywsu | | | | | | | | | | | | | | | | | | | | | | | | | 10 |

Comments:

For complete information about our services and locations please visit us at www.proscience.net or call the numbers above.

Revised on 7/20/07

PLM Asbestos Chain of Custody Record

LABORATORY/HEADQUARTERS

22 Cummings Park, Woburn, MA 01801

T:781-935-3212 F:781-932-4857

LABORATORY SERVICES

683 North Mountain Rd., Newington, CT 06111

T:860-953-1022 F:860-953-1030

☐ RUSH

Turn Around Time Requested

☐ Same day ☐ 24 Hour ☐ 48 Hour ☒ 72 Hour ☐ 5 Days

Client: Environmental Compliance Services, ECS

Address: Agawam

Project Site & Number:

Phone / FAX Number:

Contact:

91-000000.99 James' House

413-789-3530 / 413-789-2776

MS (Oe) 10

Relinquished by/date:

Received by/date:

Samples received:

Faxed, E-mailed, Verbal by/date:

Stop on first positive: Yes

For Lab Use>

Batch Number/

Analvzed by/date:

QC by/date:

[illegible]

Comments:

For complete information about our services and locations please visit us at www.proscience.net or call the numbers above.

Revised on 7/20/07